

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:43 pm

PWS ID: UTAH23007 **Name:** VERNON WATERWORKS SPECIAL SERVICE DIS
Legal Contact: VERNON WATERWORKS SPECIAL SER' **Rating:** Approved
DARRELL HOLDEN **Rating Date:** 05/17/2004
Address: BOX 51 **Activity Status:** Active
VERNON, UT 84080
Phone Number: 435-839-3464
City Served (Area):
County: TOOELE COUNTY
System Type: Community **Last Inv Update:** 05/27/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/17/2008 **Total Dsgn Cap:**
Population: 300 **Surveyor:** VICKIE ROLFE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	HOLDEN, DARRELL		435-839-3464		v4bar@wirelessbehive.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	64
Commercial	Unknown	0	5
			69 Total Svc Connections

Storage

Total Storage: 150,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	150K TANK	Ground	150,000 GAL	Concrete		A	NO
ST002	WOOD TANK (ABANDONED)	Ground		Steel		I	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP002	PUMPED WELL CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	SURGE TANK PUMP STATION	I					

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	FLOWING WELL (ABANDON	Inactive	WL	2	8 GPM		Yes	GW	Other		
WS002	FLOWING WELL #2 (ABAND	Inactive	WL	2	2 GPM		Yes	GW	Other		
WS003	FLOWING WELL #3 (ABAND	Inactive	WL	2	2 GPM		Yes	GW	Other		
WS004	PUMPED WELL	Active	WL	8	55 GPM		Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*